

Development Review Committee Comments | 8/1/2023 Case PLAT23-0046 Glenann Addition (8620 Amundson Dr)

WRITTEN STATEMENT OF CONDITIONS

The City of North Richland Hills received this plat on July 19, 2023. The Development Review Committee reviewed this plat on August 1, 2023. The following represents the written statement of the conditions for conditional approval of the plat.

- 1. The County clerk recording block may be removed from the drawing. Plats are recorded electronically, and the block is not necessary. NRH Subdivision Regulations §110-333 (Additional requirements for plat drawings county certification)
- 2. Revise the lot numbers Lots 30 and 31 in the title block. NRH Subdivision Regulations §110-331 (Requirements for all plat drawings subdivision name)
- 3. Add the City Council approval block to the plat. NRH Subdivision Regulations §110-333 (Additional requirements for plat drawings city council approval certification)

WHEREAS the City Council of the City of North Richland Hills, Texas, voted affirmatively on this day of, 20, to approve this plat for filing of record.	
Mayor, City of North Richland Hills	
Attest: City Secretary	

- 4. The zoning for the property requires a front building line of 20 feet adjacent to the Amundson Drive frontage. Add the building line to the plat. NRH Subdivision Regulations §110-331 (Requirements for all plat drawings building setback lines)
- 5. Add a sight visibility easement (15 ft by 70 ft) at the corner of Amundson Drive and Simmons Road as shown on the marked-up plat. NRH Zoning Ordinance §118-714 (Visibility sight triangles)
- 6. Add a 10-foot by 10-foot corner clip right-of-way dedication at the corner of Amundson Drive and Simmons Road as shown on the marked-up plat. NRH Subdivision Regulations Article XI Design Criteria §110-412 (Generally corner clip)
- 7. Add the following note to the plat: The easements indicated on this plat are for the purpose of constructing, using, and maintaining public utilities including underground conduits, manholes, pipes, valves, posts, above ground cables, wires, or combinations thereof, together with the right of ingress and egress to operate and maintain the public utilities. NRH Subdivision Regulations §110-331 (Requirements for all plat drawings plat notes and conditions)
- 8. Add the following note to the plat: No above ground franchise utility appurtenances are allowed in the fronts of the properties. NRH Subdivision Regulations §110-331 (Requirements for all plat drawings plat notes and conditions)
- 9. Revise the TEXRail label to reference the current ownership as shown in the public tax records: Regional Rail ROW Co. Revise the spelling of <u>railroad</u> in the label. NRH Subdivision Regulations §110-331 (Requirements for all plat drawings adjacent properties)

DESIGN PRINCIPLES

The following comments represent suggested modifications to the plat drawing based on general NRH design principles and standard practices in city planning. While conformance to these principles is not required by the subdivision regulations, the applicant is encouraged to include these modifications as part of the revised plat.

- 1. Add the City case number near the bottom right corner of the drawings (Case PLAT23-0047).
- 2. A markup of the civil plans associated with this project will be provided separately. For questions concerning the civil plan comments, contact Nathan Frohman at 817.427.6410 or nfrohman@nrhtx.com.
- 3. <u>Informational comments</u>. These comments are informational only and do not need to be added to the drawing.
 - a. Lot 30 will be addressed as 6825 Simmons Road.
 - b. Lot 31 will be addressed as 6829 Simmons Road.

