



CITY COUNCIL MEMORANDUM

FROM: The Office of the City Manager **DATE:** December 8, 2025
SUBJECT: Consider authorizing the purchase of three permanently mounted generators and automatic transfer switches to service Fire Station #1, Fire Station #4, and Fire Station #5 utilizing Sourcewell Cooperative Contract No. 092222-CMM in the amount of \$612,431.
PRESENTER: Chris Amarante, Director of Facilities & Construction

SUMMARY:

City Council is being asked to authorize the purchase of three permanently mounted generators and automatic transfer switches to service Fire Station #1, Fire Station #4, and Fire Station #5 utilizing Sourcewell Cooperative Contract No. 092222-CMM in the amount of \$612,431.

GENERAL DESCRIPTION:

This purchase is part of Capital Improvement Projects FC2601 (Fire Station #1), FC2512 (Fire Station #4), and FC2520 (Fire Station #5), which consist of the installation of permanently mounted generators, transfer switches and all the necessary installation steps. This item is for the purchase of the generators and automatic transfer switches.

The itemized equipment included in this purchase are:

- (2) Cummins 250DQDAA Diesel Genset, 60 HZ, 250kW
- (1) Cummins C200D6D Diesel Genset, 60 Hz, 200kW
- (2) Transfer Switch, PowerCommand, 800 Amp
- (1) Transfer Switch, PowerCommand, 1200 Amp

Fire stations are critical facilities for our first responders, and the continuous provision of electricity is a requirement. Installation design for this project is complete and initiating the purchase of generators at this time requires a lead time of 30 weeks with the automatic transfer switch lead time of 25 weeks. Staff will begin the competitive bidding process for installation once an estimated time of delivery for the equipment is received.

RECOMMENDATION:

Authorize the purchase of three permanently mounted generators and automatic transfer switches to service Fire Station #1, Fire Station #4, and Fire Station #5 utilizing Sourcewell Cooperative Contract No. 092222-CMM in the amount of \$612,431.